



Designation: D7619 – 22

Standard Test Method for Sizing and Counting Particles in Light and Middle Distillate Fuels, by Automatic Particle Counter^{1,2}

This standard is issued under the fixed designation D7619; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the U.S. Department of Defense.

1. Scope*

1.1 This test method uses a specific automatic particle counter² (APC) to count and measure the size of dispersed dirt particles, water droplets and other particles, in light and middle distillate fuel, and bio fuels such as biodiesel and biodiesel blends, in the overall range from 4 $\mu\text{m(c)}$ to 100 $\mu\text{m(c)}$ and in the size bands $\geq 4 \mu\text{m(c)}$, $\geq 6 \mu\text{m(c)}$, and $\geq 14 \mu\text{m(c)}$.

NOTE 1—ASTM and military specification fuels falling within the scope of this test method include Specifications: **D975** grades 1D and 2D, **D1655**, **D3699**, **D4814** (see 14.1.1.1), **D6751**, **D7467**, distillate grades of **D396** and **D2880**, MIL-DTL-83133, and MIL-DTL-16884.

NOTE 2—For the purposes of this test method, water droplets are counted as particles, and agglomerated particles are detected and counted as a single larger particle. Dirt includes biological particles. Although the projected area of a particle is measured, this is expressed as the diameter of a sphere for the purposes of this test method.

NOTE 3—The notation (c), used with particle sizes, is used to denote that the apparatus has been calibrated in accordance with ISO 11171. Strictly this only applies to particles up to 50 μm .

NOTE 4—This test method may be used for particle sizes bands up to 100 $\mu\text{m(c)}$, however the precision has only been determined for the size bands $\geq 4 \mu\text{m(c)}$, $\geq 6 \mu\text{m(c)}$, and $\geq 14 \mu\text{m(c)}$. All measurements are per millilitre.

1.2 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

¹ This test method is under the jurisdiction of ASTM Committee **D02** on Petroleum Products, Liquid Fuels, and Lubricants and is the direct responsibility of Subcommittee **D02.14** on Stability, Cleanliness and Compatibility of Liquid Fuels.

Current edition approved April 1, 2022. Published May 2022. Originally approved in 2010. Last previous edition approved in 2017 as D7619 – 17. DOI: 10.1520/D7619-22.

² The sole source of the apparatus known to the committee at this time is SETA-AvCount, available from Stanhope-Seta, London Street, Chertsey, Surrey KT16 8AP UK. If you are aware of alternative suppliers, please provide this information to ASTM International Headquarters. Your comments will receive careful consideration of a meeting of the responsible technical committee,¹ which you may attend.

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:³

D396 Specification for Fuel Oils

D975 Specification for Diesel Fuel

D1655 Specification for Aviation Turbine Fuels

D2880 Specification for Gas Turbine Fuel Oils

D3699 Specification for Kerosine

D4057 Practice for Manual Sampling of Petroleum and Petroleum Products

D4175 Terminology Relating to Petroleum Products, Liquid Fuels, and Lubricants

D4177 Practice for Automatic Sampling of Petroleum and Petroleum Products

D4814 Specification for Automotive Spark-Ignition Engine Fuel

D5854 Practice for Mixing and Handling of Liquid Samples of Petroleum and Petroleum Products

D6300 Practice for Determination of Precision and Bias Data for Use in Test Methods for Petroleum Products, Liquid Fuels, and Lubricants

D6751 Specification for Biodiesel Fuel Blend Stock (B100) for Middle Distillate Fuels

D7467 Specification for Diesel Fuel Oil, Biodiesel Blend (B6 to B20)

2.2 ASTM Adjuncts:⁴

ADJ6300 D2PP Determination of Precision and Bias data for Use in Test Methods for Petroleum Products

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

⁴ Out of print.

*A Summary of Changes section appears at the end of this standard

2.3 ISO Standards:⁵

ISO 11171 Hydraulic Fluid Power—Calibration of Automatic Particle Counters for Liquids

ISO 4406 Hydraulic Fluid Power—Fluids—Method for Coding Level of Contamination by Solid Particles

ISO 12103-A1 Specification for Ultra Fine Test Dust (UFTD)

ISO 12103-A3 Specification for Medium Test Dust (MTD)

2.4 U.S. Dept. of Defense Specifications:⁶

MIL-DTL-83133 Turbine Fuel, Aviation, Kerosene Type, JP-8 (NATO F-34), NATO F-35, and JP-8+100 (NATO F-37)

MIL-DTL-16884 Fuel, Naval Distillate

2.5 Energy Institute Standard:⁷

IP 565 Determination of the level of cleanliness of aviation turbine fuel—Portable automatic particle counter method

3. Terminology

3.1 Definitions:

3.1.1 For definitions of terms used in this test method, refer to Terminology D4175.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *coincidence error limit, n*—the highest concentration of ISO ultrafine test dust (ISO 12103-A1 or ISO UFTD) that can be counted with an automatic particle counter with less than 5 % error resulting from the presence of more than one particle in the sensor/laser optical path at a time.

3.2.2 *ISO Codes, n*—a standard method for coding the level of contamination by particles.

3.2.2.1 *Discussion*—Results are expressed by ISO Codes as specified by ISO 4406. These codes are written in the form of x/y/z, where x, y and z are ISO Codes equivalent to the cumulative counts, per mL, for particle size bands $\geq 4 \mu\text{m(c)}$, $\geq 6 \mu\text{m(c)}$, and $\geq 14 \mu\text{m(c)}$ respectively. An example of this is given in Appendix X1.

NOTE 5—All particle counts are per millilitre.

3.2.3 *particle count, n*—the sum of the number of solid particles and dispersed water droplets.

3.2.4 *particle size, $\mu\text{m(c)}$, n*—the projected area equivalent diameter of spherical particles passing through the detecting cell in accordance with ISO 11171.

3.2.5 *particle size cumulative count, n*—the total number of particles per mL, in size bands, $\geq 4 \mu\text{m(c)}$, $\geq 6 \mu\text{m(c)}$, and $\geq 14 \mu\text{m(c)}$,

3.2.5.1 *Discussion*—Automatic particle counters may also count the total number of particles per mL, in size bands, in addition to those in 3.2.5, up to $\geq 100 \mu\text{m}$.

3.2.6 *particles, n*—solid particles and dispersed water droplets which are detected and counted by this test method.

3.2.7 *test specimen, n*—an aliquot of the test sample. (See Section 10.)

4. Summary of Test Method²

4.1 The optical measurement cell comprises a light source and an optical sensor. The principle of operation is the measurement of laser light obscuration. Particles/droplets entrained within the test specimen cast shadows on the optical sensor causing a reduction of the output voltage of the sensor. The voltage drop is a function of the particle/droplet size. Each detected particle is counted, sized and recorded. Upon completion of the test the software calculates and displays the number of obscuration events for each of the predetermined size bands.

4.2 The test specimen is mixed in its container to suspend the particles. Upon initiation of a test, the automatic particle counter (APC) draws the test specimen directly from a test specimen container (see Fig. A1.1). The test sequence commences by flushing the optical measurement cell and pipework with 30 mL of the test specimen. This is immediately followed by the test of a 10 mL test specimen where particles in each of the specified size bands are counted. This flushing and measurement is then repeated. If the size band $\geq 4 \mu\text{m(c)}$, per mL, measurements agree within either 10 % or 200 counts, the measurements for each of the size bands are averaged for each size band to give results, per mL, for each size band.

5. Significance and Use

5.1 This test method is intended for use in the laboratory or in the field for evaluating the cleanliness of distillate fuels, and liquid bio fuels. It is not applicable to on or in-line applications.

5.2 This test method offers advantage over traditional filtration methods in that it is a precise rapid test, and advantage over visual methods as it is not subjective.

5.3 An increase in particle counts can indicate a change in the fuel condition caused by storage or transfer for example.

5.4 High levels of particles can cause filter blockages and have a serious impact on the life of pumps, injectors, pistons and other moving parts. Knowledge of particle size in relation to the metallurgy can provide vital information especially if the hardness of particles is also known from other sources.

5.5 This test method specifies a minimum requirement for reporting measurements in particle size bands (see A1.1.2). Some specific applications may require measurements in other particle size bands.

5.6 Obtaining a representative sample and following the recommended sample and test specimen preparation procedures and timescales is particularly important with particle counting methods. (See Sections 8, 10, 14.1.4 and Note 8.)

5.7 This test method can also be used to estimate the total particulate counts excluding free water droplets in aviation turbine fuels by a chemical pretreatment of the fuel. See Appendix X2.

6. Apparatus

6.1 *Automatic Particle Counter (APC)*²—Operating on the laser light obscuration principle, comprising an optical measurement cell, bi-directional double pump, electronics and

⁵ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

⁶ Copies of these documents are available online at <https://assist.dla.mil/quicksearch/> or <http://assistdocs.com/> or from the Standardization Document Order Desk, 700 Robbins Avenue, Building 4D, Philadelphia, PA 19111-5094.

⁷ Available from Energy Institute, 61 New Cavendish St., London, W1G 7AR, U.K., <http://www.energyinst.org>.