



Designation: E1002 – 11 (Reapproved 2022)

Standard Practice for Leaks Using Ultrasonics¹

This standard is issued under the fixed designation E1002; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 *Practice A, Pressurization*—This practice covers procedures for calibration of ultrasonic instruments, location, and estimated measurements of gas leakage to atmosphere by the airborne ultrasonic technique.²

1.2 In general practice this should be limited to leaks detected by two classifications of instruments, Class I and Class II. Class I instruments should have a minimum detectable leak rate of 6.7×10^{-7} mol/s (1.5×10^{-2} std. cm^3/s at 0°C) or more for the pressure method of gas leakage to atmosphere. Class II instruments should have a minimal detectable leak rate of 6.7×10^{-6} mol/s (1.5×10^{-1} std. cm^3/s at 0°C) or more for the pressure method of gas leakage to atmosphere. Refer to Guide E432 for additional information.

1.3 *Practice B, Ultrasonic Transmitter*—For object under test not capable of being pressurized but capable of having ultrasonic tone placed/injected into the test area to act as an ultrasonic leak trace source.

1.3.1 This practice is limited to leaks producing leakage of 6.7×10^{-6} mol/s (1.5×10^{-1} std. cm^3/s at 0°C) or greater.

1.4 The values stated in SI units are to be regarded as the standard.

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to consult and establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.6 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

¹ This practice is under the jurisdiction of ASTM Committee E07 on Nondestructive Testing and is the direct responsibility of Subcommittee E07.08 on Leak Testing Method.

Current edition approved June 1, 2022. Published July 2022. Originally approved in 1986. Last previous edition approved in 2018 as E1002 – 11(2018). DOI: 10.1520/E1002-11R22.

² This technique is sometimes called “ultrasonic translation.”

2. Referenced Documents

2.1 ASTM Standards:³

E432 Guide for Selection of a Leak Testing Method

E543 Specification for Agencies Performing Nondestructive Testing

E1316 Terminology for Nondestructive Examinations

2.2 Other Documents:

SNT-TC-1A Recommended Practice for Personnel Qualification and Certification in Nondestructive Testing⁴

ANSI/ASNT CP-189 ASNT Standard for Qualification and Certification of Nondestructive Testing Personnel⁴

NAS-410 Certification and Qualification of Nondestructive Personnel⁵

3. Terminology

3.1 *Definitions*—For definitions of terms used in this practice, see Terminology E1316, Section E.

4. Summary of Practice

4.1 *Practice A*—This practice sets minimum requirements for an ultrasonic detector (Classifications I and II). It provides for sensitivity validation of the detector and gives procedures for pressurizing the test object, locating leaks, and estimating the leakage rates.

4.2 *Practice B*—This practice sets minimum requirements for an ultrasonic detector used in conjunction with an ultrasonic transmitter. It gives procedures for locating leaks using an electronically generated ultrasonic leak tracer source.

5. Basis of Application

5.1 The following items are subject to contractual agreement between parties using or referencing this practice.

5.2 Personnel Qualification

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

⁴ Available from American Society for Nondestructive Testing (ASNT), P.O. Box 28518, 1711 Arlington Ln., Columbus, OH 43228-0518, <http://www.asnt.org>.

⁵ Available from Aerospace Industries Association of America, Inc. (AIA), 1000 Wilson Blvd., Suite 1700, Arlington, VA 22209-3928, <http://www.aia-aerospace.org>.

5.2.1 If specified in the contractual agreement, personnel performing examinations to this practice shall be qualified in accordance with a national or internationally recognized NDT personnel qualification practice or standard such as ANSI/ASNT-CP-189, SNT-TC-1A, NAS-410, or a similar document and certified by the employer or certifying agency, as applicable. The practice or standard used and its applicable revision shall be identified in the contractual agreement between the using parties.

5.3 *Qualification of Nondestructive Agencies*—If specified in the contractual agreement, NDT agencies shall be qualified and evaluated as described in Practice E543. The applicable revision of Practice E543 shall be in the contractual agreement.

6. Significance and Use

6.1 *Practice A*—This practice is useful for locating and estimating the size of pressurized gas leaks, either as a quality control test or as a field inspection procedure. It is also valuable as a pretest before other more time consuming and more sensitive leak tests are employed. It should not be used exclusively to locate highly toxic or explosive gas leaks.

6.2 *Practice B*—This practice is useful for locating leaks in systems that are not under pressure or vacuum as either a quality control or a field inspection procedure. It is not useful for estimating the size of a leak. It is also valuable as a pretest before leak tests using pressurized gas methods and more sensitive leak tests are employed.

7. Interferences

7.1 The areas to be tested must be free of oil, grease, paint, and other contaminants that might mask a leak.

7.2 Under certain conditions background noise detected by the instrument can prevent the detection of relevant leakage. This background noise can result from equipment vibration and air movement due, for example, to wind, or air-cooled motors, aircraft engines, pneumatic systems, etc.

7.3 Use of earphones is required in areas where the background noise might interfere with hearing the audible output of a speaker.

8. Apparatus

8.1 Ultrasonic Leak Detection System:

8.1.1 The system shall consist of an instrument, probes, focusing probe accessory and earphones. (A speaker may or may not be utilized.)

8.1.2 The system shall provide for detection of acoustic energy in the ultrasonic range from 20 000 to 100 000 Hz and shall translate this energy into an audible signal that can be heard by use of earphones or speaker, or both.

8.1.3 The detected energy shall be indicated on a signal level indicator.

8.2 *Minimum Instrument Requirements*—The instrument shall meet the following requirements:

8.2.1 The detected ultrasonic energy shall be indicated on a signal level indicator with a change above normal background fluctuations.

8.2.2 The audible response shall consist of the down-converted heterodyned ultrasonic signal. This audio signal will be representative of the amplitude or frequency characteristics, or both, of the original ultrasonic signal. Heterodyned signals could allow the operator to discriminate audible background interference as in 7.2.

8.2.3 The instrument shall be equipped with a sensitivity control or gain adjustment, or both, to achieve the conditions of 9.3.3.

8.2.4 The internal power supply shall be regulated to provide repeatability of the sensitivity set point to within $\pm 5\%$ of full scale over the full range of battery condition.

8.2.5 The instrument may include additional features which could enhance leak detection such as frequency controls or meter/display response selection, or both.

8.3 *Other Apparatus*—Pressure gages, valves, and piping as required.

8.4 Ultrasonic Transmission

8.4.1 The system shall consist of an apparatus described in 8.1 – 8.3 with the addition of an ultrasonic transmitter.

8.4.2 The transmitter shall produce an ultrasound peaked between the frequencies of 38 to 42 kHz.

8.4.3 The output of the transmitter transducer shall be in excess of 100 dB at 1 ft.

8.4.4 The intensity of the output may be adjustable.

8.4.5 The heterodyned signal received by the ultrasonic leak detection system from the ultrasonic transmitter must be easily identified and recognized as the ultrasonic tracer source.

8.4.6 The internal power supply shall be regulated and be sufficient to produce the required output (see 8.4.3).

8.4.7 The transmitter may include additional features that could enhance the leak detection process such as a warble tone transmission and amplitude adjustments.

9. Calibration

9.1 *Calibration/Sensitivity Validation*—The ultrasonic instrument should be calibrated or have the sensitivity validated before each initial use.

9.2 *Calibration/Sensitivity Validation Equipment*—Use the following equipment for calibration of the test system:

NOTE 1—This equipment serves a dual function; either to calibrate the ultrasonic instrument for leakage rate approximation as in 11.3, or to verify the sensitivity for detection and location as in 11.1.

9.2.1 *Leak Standard*, with a preset flow rate of 6.7×10^{-5} mol/s (1.5 std. cm³/s at 0 °C) $\pm 5\%$ for both Class I and Class II instruments. The orifice size shall be approximately 0.2 mm [0.008 in.].

9.2.2 *Regulator*, for the nitrogen supply with output pressure and flow gages. The tank pressure gage is optional.

9.3 Air Probe Sensitivity Validation:

9.3.1 For Class I instruments, locate the detection probe a distance of 10.0 m (± 0.1 m) from the calibrated leak standard specified in 9.2.1. For Class II instruments, place the detection probe a distance of 5.0 m (± 0.1 m) from the calibrated leak specified in 9.2.1.

9.3.2 Check to see that the detector probe and leak source are aligned to obtain the peak response (see Fig. 1).