



Designation: E2681 – 21

Standard Guide for Environmental Management of Underground Storage Tank Systems Storing Regulated Substances¹

This standard is issued under the fixed designation E2681; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

INTRODUCTION

This guide provides an overview of environmental practices for design, installation, operation, maintenance including scheduled inspections and periodic equipment testing, and when necessary, and corrective action for underground tank systems used for storage of regulated substances. The training for, and application of these practices should serve to prevent accidental releases of petroleum or regulated from underground storage tank systems and to facilitate effective detection and response when and if such releases do occur. The guide is intended for use by tank system owners and operators and other persons concerned with practices for prevention and control of environmental releases and remediation of affected environmental media. The guide provides an overview of environmentally sound management practices, identifying key management considerations and referring the user to other related ASTM standards and industry guidelines for more detailed information. Regulatory requirements related to underground storage tank systems may vary by regulatory jurisdiction. This guide provides recommendations to comply with the requirements of 40 CFR Part 280. The user must review the regulations of the implementing agency to determine if it has more stringent regulatory requirements. All personal safety considerations are not addressed in this guide, and it is the responsibility of the user to identify relevant safety and health protection practices and regulations related to tank system management. Caution is warranted due to the flammable or combustible property of some materials stored in underground storage tanks. Fire codes should be followed.

1. Scope

1.1 The framework discussed in this guide is limited to facilities with underground storage tanks (USTs) storing regulated substances at ambient temperature and atmospheric pressure. This guide is not intended to provide detailed technical specifications for implementation of the approaches described in this document, nor to be used as an enforcement tool, but rather to identify the important information used for environmental management of underground tank systems. The term “must” is used where United States federal requirements apply. References to ASTM standards and other industry guidelines have been provided to address implementation of the approaches discussed in this guide. Many states and some local agencies have adopted rules that place additional responsibilities on the owners/operators of UST systems. Refer to state and local regulations that may contain additional require-

ments. It is not possible to identify all considerations or combinations of conditions pertinent to a unique underground storage tank system.

1.2 This guide addresses principal considerations related to the prevention of, and response to environmental releases from tank systems and is organized in the sections listed below:

Section 1:	Scope
Section 2:	Lists relevant ASTM Standards and other industry or regulatory guidance documents
Section 3:	Defines the key terminology used in this guide
Section 4:	Describes the significance and use of this guide
Section 5:	Tank System Design and Installation
Section 6:	Preventive Maintenance and Inspection Plan
Section 7:	Fueling Procedure
Section 8:	Dispensing Activities
Section 9:	Release Response Plan
Section 10:	Corrective Action for Affected Environmental Media
Section 11:	Tank System Closure
Section 12:	UST Management Practice and Operator Training
Appendix X1:	Recurring Release Detection and Cathodic Protection Requirements (Quick Glance) is intended to be a quick reference guide for monitoring information
Related Material:	Documents related to environmental management of underground storage tanks

¹ This guide is under the jurisdiction of ASTM Committee E50 on Environmental Assessment, Risk Management and Corrective Action and is the direct responsibility of Subcommittee E50.01 on Storage Tanks.

Current edition approved Sept. 1, 2021. Published September 2021. Originally approved in 2013. Last previous edition approved in 2013 as E2681–13. DOI: 10.1520/E2681-21.

1.3 The values stated in inch-pound units are to be regarded as standard. No other units of measurement are included in this standard.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use. Some specific hazards statements are given in Section 7 on Hazards.*

1.5 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:²

- D5745** Guide for Developing and Implementing Short-Term Measures or Early Actions for Site Remediation
- E1739** Guide for Risk-Based Corrective Action Applied at Petroleum Release Sites
- E1990** Guide for Performing Evaluations of Underground Storage Tank Systems for Operational Conformance with 40 CFR, Part 280 Regulations
- E2081** Guide for Risk-Based Corrective Action
- E2616** Guide for Remedy Selection Integrating Risk-Based Corrective Action and Non-Risk Considerations

2.2 American Petroleum Institute (API) Standards:³

- API RP 1007** Loading and Unloading of MC-306 and DOT-406 Cargo Tank Motor Vehicles
- API RP 1604** Closure of Used Underground Petroleum Storage Tanks
- API RP 1615** Installation of Underground Petroleum Storage Systems
- API RP 1621** Bulk Liquid Stock Control at Retail Outlets
- API RP 1626** Storage and Handling of Ethanol and Gasoline-Ethanol Blends at Distribution Terminals and Filling Stations
- API Publication 1628** Guide to the Assessment and Remediation of Underground Petroleum Releases
- API Publication 1629** Guide for Assessing and Remediating Petroleum Hydrocarbons in Soils
- API RP 1632** Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems
- API Publication 4509** Design, Construction, Operation, Maintenance and Inspection of Terminal and Tank Facilities

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from American Petroleum Institute (API), 1220 L. St., NW, Washington, DC 20005-4070, <http://www.api.org>.

2.3 Underwriters Laboratory (UL) Standards⁴

- UL 58** Standard for Steel Underground Tanks for Flammable and Combustible Liquids
- UL 87A** Power-Operated Dispensing Devices for Gasoline and Gasoline/Ethanol Blends With Nominal Ethanol Concentrations Up To 85 Percent (E0 - E85)
- UL 971** Standard for Nonmetallic Underground Piping for Flammable Liquids
- UL 1316** Glass-Fiber-Reinforced Plastic Underground Storage Tanks for Petroleum Products, Alcohols, and Alcohol-Gasoline Mixtures
- UL 1746** Standard for External Corrosion Protection Systems for Steel Underground Storage Tanks

2.4 National Association of Corrosion Engineers (NACE) Standards⁵

- NACE RP0285** Control of External Corrosion on Underground or Submerged Metallic Piping Systems
- NACE Corrosion Data Survey** Metals and Nonmetals Sections. Hamner, N.E. (ed.), 1975

2.5 National Fire Protection Association (NFPA) Standards:⁶

- NFPA 30** Flammable and Combustibles Liquids Code
- NFPA 30A** Code for Motor Fuel Dispensing Facilities and Repair Garages
- NFPA 326** Standard for the Safeguarding of Tanks and Containers for Entry, Cleaning, or Repair
- NFPA 385** Standard for Tank Vehicles for Flammable and Combustible Liquids

2.6 Petroleum Equipment Institute (PEI) Standards:⁷

- PEI RP100** Recommended Practice for Installation of Underground Liquid Storage Systems
- PEI RP900** Recommended Practices for the Inspection and Maintenance of UST Systems

2.7 Steel Tank Institute (STI) Standards:⁸

- STI-P3** System for External Corrosion Protection of Underground Steel Storage Tanks
- STI F841-01** Standard for Dual Wall Underground Steel Storage Tanks
- STI ACT-100** External Corrosion Protection of FRP Composite Steel Underground Storage Tanks
- STI ACT-100-U** External Corrosion Protection of Composite Steel Underground Storage Tanks
- STI Document** "Keeping Water Out of Your Storage System"
- STI F922** PERMATANK (trademarked) Double Wall Steel-Fiberglass Underground Storage Tank

⁴ Available from Underwriters Laboratories (UL), 2600 N.W. Lake Rd., Camas, WA 98607-8542, <http://www.ul.com>.

⁵ Available from NACE International (NACE), 1440 South Creek Dr., Houston, TX 77084-4906, <http://www.nace.org>.

⁶ Available from National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02169-7471, <http://www.nfpa.org>.

⁷ Available from Petroleum Equipment Institute (PEI), P.O. Box 2380, Tulsa, OK 74101-2380, <http://www.pei.org>.

⁸ Available from Steel Tank Institute (STI), 944 Donata Ct., Lake Zurich, IL 60047, <http://www.steeltank.com>.