



Standard Test Method for Reporting Photovoltaic Non-Concentrator System Performance¹

This standard is issued under the fixed designation E2848; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method provides measurement and analysis procedures for determining the capacity of a specific photovoltaic system built in a particular place and in operation under natural sunlight.

1.2 This test method is used for the following purposes:

1.2.1 Acceptance testing of newly installed photovoltaic systems,

1.2.2 Reporting of dc or ac system performance, and

1.2.3 Monitoring of photovoltaic system performance.

1.3 This test method should not be used for:

1.3.1 Testing of individual photovoltaic modules for comparison to nameplate power ratings,

1.3.2 Testing of individual photovoltaic modules or systems for comparison to other photovoltaic modules or systems, and

1.3.3 Testing of photovoltaic systems for the purpose of comparing the performance of photovoltaic systems located in different places.

1.4 In this test method, photovoltaic system power is reported with respect to a set of reporting conditions (RC) including solar irradiance in the plane of the modules, ambient temperature, and wind speed (see Section 6). Measurements under a variety of reporting conditions are allowed to facilitate testing and comparison of results.

1.5 This test method assumes that the solar cell temperature is directly influenced by ambient temperature and wind speed; if not the regression results may be less meaningful.

1.6 The capacity measured according to this test method should not be used to make representations about the energy generation capabilities of the system.

1.7 This test method is not applicable to concentrator photovoltaic systems; as an alternative, Test Method E2527 should be considered for such systems.

1.8 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.9 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.10 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASTM Standards:*²

D6176 Practice for Measuring Surface Atmospheric Temperature with Electrical Resistance Temperature Sensors

E772 Terminology of Solar Energy Conversion

E824 Test Method for Transfer of Calibration From Reference to Field Radiometers

E927 Classification for Solar Simulators for Electrical Performance Testing of Photovoltaic Devices

E948 Test Method for Electrical Performance of Photovoltaic Cells Using Reference Cells Under Simulated Sunlight

E973 Test Method for Determination of the Spectral Mismatch Parameter Between a Photovoltaic Device and a Photovoltaic Reference Cell

E1036 Test Methods for Electrical Performance of Nonconcentrator Terrestrial Photovoltaic Modules and Arrays Using Reference Cells

E1040 Specification for Physical Characteristics of Nonconcentrator Terrestrial Photovoltaic Reference Cells

E1125 Test Method for Calibration of Primary Non-Concentrator Terrestrial Photovoltaic Reference Cells Using a Tabular Spectrum

¹ This test method is under the jurisdiction of ASTM Committee E44 on Solar, Geothermal and Other Alternative Energy Sources and is the direct responsibility of Subcommittee E44.09 on Photovoltaic Electric Power Conversion.

Current edition approved Aug. 1, 2023. Published August 2023. Originally approved in 2011. Last previous edition approved in 2018 as E2848 – 13 (2018). DOI: 10.1520/E2848-13R23.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

- E1362 Test Methods for Calibration of Non-Concentrator Photovoltaic Non-Primary Reference Cells
- E2527 Test Method for Electrical Performance of Concentrator Terrestrial Photovoltaic Modules and Systems Under Natural Sunlight
- G138 Test Method for Calibration of a Spectroradiometer Using a Standard Source of Irradiance
- G167 Test Method for Calibration of a Pyranometer Using a Pyrheliometer
- G173 Tables for Reference Solar Spectral Irradiances: Direct Normal and Hemispherical on 37° Tilted Surface
- G183 Practice for Field Use of Pyranometers, Pyrheliometers and UV Radiometers

2.2 IEEE Standards:

- IEEE 1526-2003 Recommended Practice for Testing the Performance of Stand-Alone Photovoltaic Systems
- IEEE 1547-2003 Standard for Interconnecting Distributed Resources with Electric Power Systems

2.3 International Standards Organization Standards:

- ISO/IEC Guide 98-1:2009 Uncertainty of measurement—Part 1: Introduction to the expression of uncertainty in measurement
- ISO/IEC Guide 98-3:2008 Uncertainty of measurement—Part 3: Guide to the expression of uncertainty in measurement (GUM:1995)

- 2.4 World Meteorological Organization (WMO) Standard: WMO-No. 8 Guide to Meteorological Instruments and Methods of Observation, Seventh Ed., 2008

3. Terminology

3.1 *Definitions*—Definitions of terms used in this test method may be found in Terminology E772, IEEE 1547-2003, and ISO/IEC Guide 98-1:2009 and ISO/IEC Guide 98-3:2008.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *averaging interval, n*—the time interval over which data are averaged to obtain one data point. The performance test uses these averaged data.

3.2.2 *data collection period, n*—the period of time defined by the user of this test method during which system output power, irradiance, ambient temperature, and wind speed are measured and recorded for the purposes of a single regression analysis.

3.2.3 *plane-of-array irradiance, POA, n*—see *solar irradiance, hemispherical* in Tables G173.

3.2.4 *reporting conditions, RC, n*—an agreed-upon set of conditions including the plane-of-array irradiance, ambient temperature, and wind speed conditions to which photovoltaic system performance are reported. The reporting conditions must also state the type of radiometer used to measure the plane-of-array irradiance. In the case where this test method is to be used for acceptance testing of a photovoltaic system or reporting of photovoltaic system performance for contractual purposes, RC, or the method that will be used to derive the RC, shall be stated in the contract or agreed upon in writing by the parties to the acceptance testing and reporting prior to the start of the test.

3.2.5 *sampling interval, n*—the elapsed time between scans of the sensors used to measure power, irradiance, ambient temperature, and wind speed. Individual data points used for the performance test are averages of the values recorded in these scans. There are multiple sampling intervals in each averaging interval.

3.2.6 *utility grid, n*—see **electric power system** in IEEE 1547-2003.

3.3 *Symbols*: The following symbols and units are used in this test method:

- 3.3.1 α —reference cell I_{SC} temperature coefficient, $^{\circ}\text{C}^{-1}$
- 3.3.2 a_1, a_2, a_3, a_4 —linear regression coefficients, arbitrary
- 3.3.3 a, b, c, d —spectral mismatch factor calibration constants, arbitrary
- 3.3.4 C —reference cell calibration constant, Am^2W^{-1}
- 3.3.5 C_o —reference cell calibration constant at SRC, Am^2W^{-1}
- 3.3.6 E —plane-of-array irradiance, W/m^2
- 3.3.7 E_o —irradiance at SRC, plane-of-array, W/m^2
- 3.3.8 $E_o(\lambda)$ —reference spectral irradiance distribution, $\text{Wm}^{-2}\text{nm}^{-1}$
- 3.3.9 E_{RC} —RC rating irradiance, plane-of-array, W/m^2
- 3.3.10 $E_{RC}(\lambda)$ —spectral irradiance distribution at RC, $\text{Wm}^{-2}\text{nm}^{-1}$
- 3.3.11 $E_T(\lambda)$ —spectral irradiance distribution, test light source, $\text{Wm}^{-2}\text{nm}^{-1}$
- 3.3.12 F —fractional error in short-circuit current, dimensionless
- 3.3.13 I_{SC} —short-circuit current, A
- 3.3.14 M —spectral mismatch factor, dimensionless
- 3.3.15 p —p-value, dimensionless quantity used to determine the significance of an individual regression coefficient to the overall rating result
- 3.3.16 P —photovoltaic system power, ac or dc, W
- 3.3.17 P_{RC} —photovoltaic system power at RC, ac or dc, W
- 3.3.18 RC —reporting conditions
- 3.3.19 $R_R(\lambda)$ —reference cell spectral responsivity, A/W
- 3.3.20 $R_T(\lambda)$ —test device spectral responsivity, A/W
- 3.3.21 SRC —standard reporting conditions
- 3.3.22 SE —standard error, W
- 3.3.23 T_a —ambient temperature, $^{\circ}\text{C}$
- 3.3.24 T_{RC} —RC rating temperature, $^{\circ}\text{C}$
- 3.3.25 U_{95} —expanded uncertainty with a 95 % coverage probability of photovoltaic system power at RC, W
- 3.3.26 λ —wavelength, nm
- 3.3.27 v —wind speed, m/s
- 3.3.28 v_{RC} —RC rating wind speed, m/s