



Standard Test Method for Resistance to Wildfire Penetration of Eaves, Soffits and Other Projections¹

This standard is issued under the fixed designation E2957; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This fire-test-response standard prescribes a method for qualitatively assessing the resistance to fire penetration of eave overhangs and other projections, such as the soffits of roof eaves and cantilevered floor projections, when exposed to direct flame impingement from a simulated external wildfire exposure, such as encountered in a “Wildland Urban Interface” scenario. This test method provides data suitable for comparing the relative performance of materials, which are used as the exposed underside surfaces of eave overhangs and other projections.

1.2 This test method measures the ability of eave overhangs and other projections to resist fire penetration from the exterior into the wall cavity or unexposed side of the test specimen under the conditions of exposure.

1.3 This test method is applicable to eave overhangs and other projections such as the soffits of roof eaves and cantilevered floor projections intended for use with either combustible or noncombustible building envelopes.

1.4 Limitations of the test method are listed in Section 5.

1.5 The values stated in metric units are to be regarded as the standard. Values in parentheses are for information only.

1.6 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.7 *This standard is used to measure and describe the response of materials, products, or assemblies to heat and flame under controlled laboratory conditions, but does not by itself incorporate all factors required for fire hazard or fire risk assessment of the materials, products or assemblies under actual fire conditions.*

1.8 *Fire testing is inherently hazardous. Adequate safeguards for personnel and property shall be employed in conducting these tests.*

1.9 *The text of this standard references notes and footnotes which provide explanatory material. These notes and footnotes (including those in tables and figures) shall not be considered as requirements of the standard.*

1.10 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:²

- C1396/C1396M Specification for Gypsum Board
- D2898 Practice for Accelerated Weathering of Fire-Retardant-Treated Wood for Fire Testing
- D4442 Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials
- D4444 Test Method for Laboratory Standardization and Calibration of Hand-Held Moisture Meters
- D6662 Specification for Polyolefin-Based Plastic Lumber Decking Boards
- D7032 Specification for Establishing Performance Ratings for Wood-Plastic Composite and Plastic Lumber Deck Boards, Stair Treads, Guards, and Handrails
- E176 Terminology of Fire Standards
- E631 Terminology of Building Constructions
- E2707 Test Method for Determining Fire Penetration of Exterior Wall Assemblies Using a Direct Flame Impingement Exposure
- E2912 Test Method for Fire Test of Non-Mechanical Fire Dampers Used in Vented Construction
- E2886/E2886M Test Method for Evaluating the Ability of Exterior Vents to Resist the Entry of Embers and Direct Flame Impingement

¹ This test method is under the jurisdiction of ASTM Committee E05 on Fire Standards and is the direct responsibility of Subcommittee E05.14 on External Fire Exposures.

Current edition approved June 1, 2024. Published June 2024. Originally approved in 2015. Last previous edition approved in 2017 as E2957-17. DOI: 10.1520/E2957-17R24.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at www.astm.org/contact. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

2.2 Other Standards:

ISO 13943 Fire Safety—Vocabulary³

NFPA 286 Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth⁴

3. Terminology

3.1 Definitions—For definitions of terms used in this standard, see Terminology **E176**, **E631** and ISO 13943. In case of conflict between **E176** and **E631** or ISO 13943, the definitions given in Terminology **E176** shall prevail. In case of conflict between **E631** and ISO 13943, the definitions given in Terminology **E631** shall prevail.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 building envelope, *n*—the boundary or barrier separating different environmental conditions within a building and from the outside environment.

3.2.2 eave, *n*—a projecting edge of a roof that extends beyond the building envelope.

3.2.3 glow, *n*—visible light emitted by a solid undergoing combustion.

3.2.4 holding fixture, *n*—apparatus designed to hold the test specimen and a wall assembly, described in **7.3**.

3.2.5 projection, *n*—an exterior outcrop of the building, such as a cantilevered room, that protrudes from or overhangs the building envelope.

3.2.5.1 Discussion—Examples include, but are not limited to, eaves, soffits, enclosed cantilevered balconies, and enclosed cantilevered room bump-outs.

3.2.6 soffit, *n*—the enclosed underside of any exterior overhanging section of a roof eave.

3.2.7 sustained flaming, *n*—flame on or over the surface of a test specimen that lasts longer than a period of 4 s.

3.2.8 wall assembly, *n*—framed vertical section simulating an exterior wall below an eave overhang or projection used in the evaluation of test specimen.

3.2.8.1 Discussion—Paragraph **7.2** describes the wall assembly used in this test method.

4. Summary of Test Method

4.1 This test method provides for the direct flame exposure of eave overhang and other projections.

4.2 This test method employs a gas burner to produce a diffusion flame in contact with the test specimen.

4.3 The flame source is centered left to right and below the test specimen.

4.4 The gas burner produces a prescribed net rate of heat output during the flame exposure period, after which the flame exposure is terminated.

4.5 The test method monitors the fire characteristics and the ability of the test specimen to resist fire penetration during the flame exposure period and a subsequent observation period.

4.6 Observations are made for the appearance of sustained flaming and glow on the unexposed side during the 10-min flame exposure period and a subsequent 30-min observation period.

5. Significance and Use

5.1 The test method described herein monitors the fire characteristics and the ability of eave overhangs and other projections to resist exterior fire penetration from underneath under the specified fire exposure conditions.

5.2 Representative joints and other characteristics of the eave overhang or projection shall be included in the test specimen when these details are representative of the end-use construction.

5.3 The test method does not apply to vents or perforated materials used to enclose or cap eaves, soffits, and other projections.

NOTE 1—Test Methods **E2912** and **E2886/E2886M** are methods used to test vents or perforated materials to resist direct flame impingement and flame penetration into the building.

5.4 The test method is devised for eave overhangs and other projections independent of the materials covering the building envelope.

NOTE 2—Heat contribution from burning materials covering the building envelope beyond the prescribed fire exposure is not considered in this test method.

5.5 The test method does not necessarily represent the expected performance of eave overhang and projections under all actual fire conditions, but it does provide a basis for comparing eave overhang and projections materials when subjected to the test procedure described herein.

5.6 In this procedure, the test specimen is subjected to specific laboratory fire test conditions. If different test conditions are substituted or the anticipated end-use conditions are changed, it is not known whether it is possible by use of this test to predict changes in the performance characteristics measured. Therefore, the results are strictly valid only for the fire test conditions and construction tested.

5.7 The test method does not provide any basis for determining the fire resistance characteristics of eave overhangs or projections when exposed to a fire originating in the building.

5.8 The test method does not address interior or exterior flame spread.

6. Safety Precautions

6.1 The test procedure involves high temperatures and combustion processes. Therefore, the potential exists for burns, ignition of extraneous objects or clothing, and for inhalation of combustion products.

7. Apparatus

7.1 Unless otherwise noted, dimensions in the following descriptions shall be followed with a tolerance of ± 13 mm (0.5 in.).

³ Available from International Organization for Standardization (ISO), 1, ch. de la Voie-Creuse, CP 56, CH-1211 Geneva 20, Switzerland, <http://www.iso.org>.

⁴ Available from National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02169-7471, <http://www.nfpa.org>.