



Standard Guide for Selection and Use of Full-Encirclement-Type Band Clamps for Reinforcement or Repair of Punctures or Holes in Polyethylene Gas Pressure Pipe¹

This standard is issued under the fixed designation F1025; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope*

1.1 This guide specifically addresses the design and installation of full-encirclement-type band clamps for repair of gouges, punctures, or holes, and for reinforcement of polyethylene plastic pipe. Guidelines are provided for selecting and using clamps in pipe sizes 2 in. nominal (60 mm) and larger.

1.1.1 A test method is also provided for the user to assess the applicability of the repair clamp. Under appropriate circumstances, this type of clamp offers a convenient, effective, and safe means of restoring the integrity of an in-service pipeline, without cutting out a section of pipe (see **Note 1**). The pipe to be repaired cannot be backed by a stiffener for internal support and cross-sectional dimensional control. Satisfactory use of this type of clamp should rely on the crush resistance of the pipe itself and a fitting design concept, which retains the cross-sectional pipe configuration while minimizing compressive forces required to obtain an effective leakage seal.

NOTE 1—The appropriateness for use of this type of clamp should be determined by using the information contained in this guide and from consultation with, and recommendations of, both the pipe and clamp manufacturers. The basic premise for use of this type of clamp is that it is recommended by the manufacturer for this specific application and that step-by-step installation instructions are available for that application. It is important in the development of this type of clamp that prototype testing be conducted to evaluate performance expectations because of the physical limitations encountered when designing it for use with plastic pipe.

1.2 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

¹ This guide is under the jurisdiction of ASTM Committee F17 on Plastic Piping Systems and is the direct responsibility of Subcommittee F17.60 on Gas.

Current edition approved Aug. 1, 2025. Published August 2025. Originally approved in 1986. Last previous edition approved in 2019 as F1025 – 19. DOI: 10.1520/F1025-19R25.

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:²

F1041 Guide for Squeeze-Off of Polyolefin Gas Pressure Pipe and Tubing

3. Terminology

3.1 Definitions of Terms Specific to This Standard:

3.1.1 *creep*—the time-dependent part of strain resulting from stress, that is, dimensional change caused by the application of load over and above the elastic deformation and with respect to time.

4. Significance and Use

4.1 Full-encirclement-type band clamps are recommended for repairs only where the pipe is able to maintain its structural integrity. These clamps are not recommended for permanent repair of pipe where the damage could propagate outside the clamp under anticipated field conditions (see 5.1.1 for repair limitations). In such situations, it is recommended to cut out and replace the damaged pipe with a new piece. Clamps that are used for repair should comply with the manufacturer's specifications for use and the manufacturer's installation instructions should be followed.

4.2 These clamps may be used to cover holes left in the pipe from abandoned service line connections, purge points, and accidental punctures.

4.3 These clamps may be used to reinforce the pipe where the wall thickness has been reduced because of gouges or other irregularities.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at www.astm.org/contact. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

*A Summary of Changes section appears at the end of this standard