



Standard Practice for Selection of Valve Operators¹

This standard is issued under the fixed designation F1030; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice provides guidance in the selection of manual and power-actuated valve operators.

1.2 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASME Standards:*²

B16.5 Pipe Flanges and Flanged Fittings: NPS 1/2 through NPS 24 Metric/Inch Standard

3. List of Valve Operator Types

3.1 *Manual Operators:*

3.1.1 Handwheels.

3.1.2 Tee-wrenches.

3.2 *Electric Operators:*

3.2.1 Stem Nut Driven.

3.2.2 Handwheel Driven.

3.3 *Pneumatic Operators:*

3.3.1 Stem Nut Driven.

3.3.2 Handwheel Driven.

3.4 *Hydraulic Operators:*

3.4.1 Stem Nut Driven.

3.4.2 Handwheel Driven.

4. General Requirements

4.1 General requirements apply to all types of valve operators.

4.2 Operating terminals shall be accessible during all service conditions but shall not constitute an obstruction in working spaces.

4.3 Valve controls that are not immediately identifiable as to service shall be fitted with name plates.

4.4 Valve operating stations shall be fitted with a valve position indicator unless valve position is obvious for the service intended (full open or full closed), or valve is classified damage control smaller than 1½ in. (38.1 mm).

4.5 Positioning of the valve by either the local or remote actuators shall not void the ability of any other actuator to position the valve.

4.6 All valves, regardless of size, shall be readily operable by one man in a reasonable and limited time period, either through a manual or power-actuated valve operator.

5. Manual Valve Operators

5.1 Material for handwheels and tee-wrenches for casualty or damage control shall be either malleable iron, ductile iron, or steel.

5.2 Portable valve wrenches shall be labeled and stored near the valve operating station. Valve operating wrenches shall fit and turn (to open and close) deckbox operator covers.

5.3 Valves shall be located to prevent the necessity for ratchet wrenches wherever possible. Ratchet wrenches are, however, permitted where valve location prevents complete wrench rotation.

5.4 Handwheel diameter and tee-wrench handle length, based on the system torque at the operating station, is presented in **Table 1**.

6. Requirements for Power-Actuated Valve Operators

6.1 Requirements for power-actuated operators apply to electric, pneumatic, and hydraulic valve operators.

¹ This practice is under the jurisdiction of ASTM Committee F25 on Ships and Marine Technology and is the direct responsibility of Subcommittee F25.11 on Machinery and Piping Systems.

Current edition approved May 1, 2023. Published May 2023. Originally approved in 1986. Last previous edition approved in 2018 as F1030 – 86 (2018). DOI: 10.1520/F1030-86R23.

² Available from American Society of Mechanical Engineers (ASME), ASME International Headquarters, Two Park Ave., New York, NY 10016-5990, <http://www.asme.org>.