



Standard Specification for Spill Valves for Use in Marine Tank Liquid Overpressure Protections Applications¹

This standard is issued under the fixed designation F1271; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This specification provides the minimum requirements for design, construction, performance, and testing of devices to prevent marine tank liquid overpressurization (hereafter called spill valves).

1.2 The spill valves provided in accordance with this specification will satisfy Regulation 11-2/59.1.6 of the 1981 and 1983 Amendments to the International Convention for the Safety of Life at Sea, 1974 (SOLAS), which states: “Provision shall be made to guard against liquid rising in the venting system to a height which would exceed the design head of the cargo tank. This shall be accomplished by high level alarms or overflow control systems or other equivalent means, together with gaging devices and cargo tank filling procedures.”

1.3 The spill valves are not intended for the venting of vapors or the relief of vapor overpressurization or underpressurization of marine tanks.

1.4 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.5 The following precautionary caveat pertains only to the test methods portion, Section 8, of this specification: *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.6 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

¹ This specification is under the jurisdiction of ASTM Committee F25 on Ships and Marine Technology and is the direct responsibility of Subcommittee F25.11 on Machinery and Piping Systems.

Current edition approved May 1, 2023. Published June 2023. Originally approved in 1989. Last previous edition approved in 2018 as F1271 – 90 (2018). DOI: 10.1520/F1271-90R23.

2. Referenced Documents

2.1 ASTM Standards:²

B117 Practice for Operating Salt Spray (Fog) Apparatus
F722 Specification for Welded Joints for Shipboard Piping Systems

2.2 ANSI Standards:³

B 2.1 Pipe Threads
B 16.1 Cast Iron Pipe Flanges and Flanged Fittings
B 16.3 Malleable Iron Threaded Fittings
B 16.4 Cast Iron Threaded Fittings
B 16.5 Steel Pipe Flanges and Flanged Fittings
B 16.11 Forged Steel Fittings, Socket-Welding and Threaded
B 16.15 Cast Bronze Threaded Fittings
B 16.24 Bronze Pipe Flanges and Flanged Fittings
B 31.1 Power Piping

2.3 Other Documents:

ASME Boiler and Pressure Vessel Code, Section VIII, Division 1, Pressure Vessels; Section IX, Welding and Brazing Qualifications⁴
Safety for Life at Sea Convention, Regulation II-2/59.1.6, Amendments 1981 and 1983³
46 CFR 153 Ships Carrying Bulk Liquid, Liquefied Gas, or Compressed Gas Hazardous Materials⁵

3. Terminology

3.1 Definitions:

3.1.1 *spill valve*—an independent device that automatically prevents liquid overpressurization of a tank by relieving liquid at a predetermined pressure set higher than the pressure reached in the tank when the tank vapor relieving device

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

⁴ Available from American Society of Mechanical Engineers (ASME), ASME International Headquarters, Two Park Ave., New York, NY 10016-5990, <http://www.asme.org>.

⁵ Available from DLA Document Services, Building 4/D, 700 Robbins Ave., Philadelphia, PA 19111-5094, <http://quicksearch.dla.mil>.

operates at its maximum design venting rate (based on a volumetric vapor volume 1.25 times the maximum design loading rate).

4. Ordering Information

4.1 Orders for spill valves in accordance with this specification shall include the following information, as applicable:

- 4.1.1 Nominal pipe size and end connections,
- 4.1.2 Product(s) in tank being protected by the spill valve,
- 4.1.3 Inspection and tests other than specified by this specification,
- 4.1.4 Required relieving pressure at maximum tank loading flow rate,
- 4.1.5 Set (opening) pressure,
- 4.1.6 Maximum tank design loading flow rate,
- 4.1.7 Inlet pressure drop resulting from the maximum tank design loading flow rate,
- 4.1.8 Back pressure of the spill valve discharge lines resulting from maximum tank design loading flow rate,
- 4.1.9 Purchaser's inspection requirements (see 9.1),
- 4.1.10 Installation inclinations in excess of $2\frac{1}{2}^{\circ}$ (see 6.6),
- 4.1.11 Purchaser's specifications for preventing the valve from leaking due to cargo sloshing, and
- 4.1.12 Additional requirements or testing as contracted by the manufacturer and the purchaser.

5. Materials

5.1 Materials of construction shall be suitable for the service intended and resistant to the attack by the liquid carried in the tank being protected (see 4.1.2). Table I of 46 CFR 153 specifies materials that may not be used in components that contact liquid or vapor of each hazardous liquid cargo.

5.2 Housings of spill valves, and all other parts or bolting, or both, used for pressure retention, shall be constructed of materials having a solidus melting point of greater than 1700 °F (927 °C) and be listed in ANSI B 31.1 or Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code, except as noted in 5.5.

5.3 Corrosion-resistant materials shall be used for the following:

- 5.3.1 Housings, disks, spindles, and seats of valves.
- 5.3.2 Springs that actuate disks of valves. Springs plated with corrosion-resistant material are not acceptable.

5.4 Nonmetallic materials shall not be permitted except for gaskets, seals, bushings in way of moving parts, and valve diaphragms.

5.5 Bolting materials shall be at least equal to those listed in Table 1 of ANSI B 16.5. Bolts, screws, and fasteners in contact with interior liquid shall be compatible with the liquid (see 4.1.2).

6. Other Requirements

6.1 Pressure-retaining housings shall be designed to withstand a hydrostatic pressure of at least 125 lb/in.² (8.78 kg/cm²) without rupturing or showing permanent distortion.

6.2 Housing shall have suitable pipe connections for the removal, maintenance, and testing of the spill valve.

6.2.1 Threaded or flanged pipe end connections shall comply with the applicable B16 ANSI standards listed in 2.2 or as agreed upon by the manufacturer and the purchaser (see 4.1.12). Welded joints shall comply with Specification F722.

6.3 The design of spill valves shall allow for ease of inspection and removal of internal elements for replacement, cleaning, or repair without removal of the spill valve.

6.4 All flat joints of the housing shall be machined true and shall provide for a joint having adequate metal-to-metal contact.

6.5 Where welded construction is used, welded joint design details, welding, and nondestructive testing shall be in accordance with Section VIII, Division 1 of the ASME Code and Specification F722. Welders and weld procedures shall be qualified in accordance with Section IX of the ASME Code.

6.6 The spill valve shall be fully operable at static inclinations up to $2\frac{1}{2}^{\circ}$ unless otherwise specified by the ordering information in Section 4.

6.7 Spill valves shall allow for efficient drainage of moisture without impairing their proper operation.

6.7.1 Where the design does not permit complete drainage of condensate through its connection to the tank, the housing shall be fitted with a plugged drain opening on the side of the atmospheric outlet of not less than nominal pipe size $\frac{1}{2}$ in. (12 mm).

6.8 Housing, elements, and seal gasket materials shall be capable of withstanding the highest pressure and temperature to which the spill valve may be exposed under normal conditions.

6.9 Spill valves shall be vapor tight at pressures below the rated liquid relieving pressure.

6.10 Fastenings essential to the operation of the spill valve shall be protected against loosening.

6.11 Spill valves shall be designed and constructed to minimize the effect of fouling under normal conditions.

6.12 The spill valve shall not be provided with a means of positive closure. In installations where cargo sloshing is expected, the spill valve installation must be designed to preclude premature opening of the valve due to cargo sloshing. Also, the installation shall be designed so that it complies with applicable loadline and subdivision requirements.

6.13 Spill valves shall be capable of operating in freezing conditions.

6.14 Each of the free areas through the valve seat and through the valve discharge at maximum lift shall not be less than the cross-sectional area of the valve inlet connection.

6.15 Means shall be provided to check that any valve opens freely and does not remain lodged in the open position.

6.16 Valve Disks:

6.16.1 Valve disks shall be guided by a ribbed cage or other suitable means to prevent binding and ensure proper seating. Where valve stems are guided by bushings suitably designed to