



Standard Specification for Polyamide 11 Gas Pressure Pipe, Tubing, and Fittings¹

This standard is issued under the fixed designation F2945; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope*

1.1 This specification covers requirements and test methods for the characterization of polyamide 11 pipe, tubing, and fittings for use in fuel gas pipelines. The pipe and fittings covered by this specification are intended for use in the distribution and transmission of fuel gases.

1.1.1 This specification does not cover threaded pipe. Generic fusion guidelines are given in [Appendix X1](#). Design considerations are discussed in [Appendix X2](#). In-plant quality control programs are specified in [Annex A1](#).

1.2 The text of this specification references notes, footnotes, and appendixes which provide explanatory material. These notes and footnotes (excluding those in tables and figures) shall not be considered as requirements of the specification.

NOTE 1—Heat fusion joining of PA11 pipe and fittings meeting the requirements of this standard is limited to PA11 pipe and fittings meeting the requirements of this standard. Heat Fusion joining of PA11 pipe and fittings meeting the requirements of this standard is not allowed to pipes and fittings made from any other thermoplastic materials (for example, PA12, PEs, PVCs, etc.).

1.3 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.4 The following is an index of the annexes and appendixes in this specification:

Annexes	Subject
Annex A1	In-Plant Quality Control for sizes up to 12 in.
Annex A2	PA-11 Butt Fusion Fittings
Appendixes	Subject
Appendix X1	Butt Fusion Guidelines for PA-11 Piping
Appendix X2	Design Consideration

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.6 *This international standard was developed in accordance with internationally recognized principles on standard-*

ization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.

2. Referenced Documents

2.1 ASTM Standards:²

- [D543 Practices for Evaluating the Resistance of Plastics to Chemical Reagents](#)
- [D618 Practice for Conditioning Plastics for Testing](#)
- [D638 Test Method for Tensile Properties of Plastics](#)
- [D648 Test Method for Deflection Temperature of Plastics Under Flexural Load in the Edgewise Position](#)
- [D789 Test Method for Determination of Relative Viscosity of Concentrated Polyamide \(PA\) Solutions](#)
- [D790 Test Methods for Flexural Properties of Unreinforced and Reinforced Plastics and Electrical Insulating Materials](#)
- [D792 Test Methods for Density and Specific Gravity \(Relative Density\) of Plastics by Displacement](#)
- [D1598 Test Method for Time-to-Failure of Plastic Pipe Under Constant Internal Pressure](#)
- [D1599 Test Method for Resistance to Short-Time Hydraulic Pressure of Plastic Pipe, Tubing, and Fittings](#)
- [D1600 Terminology for Abbreviated Terms Relating to Plastics](#)
- [D1898 Practice for Sampling of Plastics \(Withdrawn 1998\)³](#)
- [D2122 Test Method for Determining Dimensions of Thermoplastic Pipe and Fittings](#)
- [D2290 Test Method for Apparent Hoop Tensile Strength of Plastic or Reinforced Plastic Pipe](#)
- [D2774 Practice for Underground Installation of Thermoplastic Pressure Piping](#)
- [D2837 Test Method for Obtaining Hydrostatic Design Basis for Thermoplastic Pipe Materials or Pressure Design Basis for Thermoplastic Pipe Products](#)

¹ This test method is under the jurisdiction of ASTM Committee F17 on Plastic Piping Systems and is the direct responsibility of Subcommittee F17.60 on Gas.

Current edition approved Nov. 1, 2023. Published November 2023. Originally approved in 2012. Last previous edition approved in 2018 as F2945–18. DOI: 10.1520/D2945–18R23.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ The last approved version of this historical standard is referenced on www.astm.org.

D3418 Test Method for Transition Temperatures and Enthalpies of Fusion and Crystallization of Polymers by Differential Scanning Calorimetry

D4066 Classification System for Nylon Injection and Extrusion Materials (PA)

F412 Terminology Relating to Plastic Piping Systems

F1025 Guide for Selection and Use of Full-Encirclement-Type Band Clamps for Reinforcement or Repair of Punctures or Holes in Polyethylene Gas Pressure Pipe

F1563 Specification for Tools to Squeeze-off Polyethylene (PE) Gas Pipe or Tubing

F1733 Specification for Butt Heat Fusion Polyamide(PA) Plastic Fitting for Polyamide(PA) Plastic Pipe and Tubing

F1973 Specification for Factory Assembled Anodeless Risers and Transition Fittings in Polyethylene (PE) and Polyamide 11 (PA11) and Polyamide 12 (PA12) Fuel Gas Distribution Systems

F2138 Specification for Excess Flow Valves for Natural Gas Service

F2145 Specification for Polyamide 11 (PA 11) and Polyamide 12 (PA12) Mechanical Fittings for Use on Outside Diameter Controlled Polyamide 11 and Polyamide 12 Pipe and Tubing

F2600 Specification for Electrofusion Type Polyamide-11 Fittings for Outside Diameter Controlled Polyamide-11 Pipe and Tubing

F2897 Specification for Tracking and Traceability Encoding System of Natural Gas Distribution Components (Pipe, Tubing, Fittings, Valves, and Appurtenances)

2.2 *ANSI Standards:*⁴

B 16.40 Manually Operated Thermoplastic Gas Shutoffs and Valves in Gas Distribution Systems

B 31.8 Gas Transmission and Distribution Piping Systems

2.3 *Federal Specifications:*⁵

Fed. Std. No. 123 Marking for Shipment (Civil Agencies)

OPS Part 192 Title 49, Title 49 Code of Federal Regulations

2.4 *Military Standards:*⁶

MIL-STD-129 Marking for Shipment and Storage

MIL-STD-1235 (ORD) Single- and Multi-Level Continuous Sampling Procedures and Tables for Inspection by Attributes

2.5 *ISO Standards:*⁷

ISO 75–1 Plastics - Determination of temperature of deflection under load - Part 1: General test method

ISO 75–2 Determination of temperature of deflection under load - Part 2: Plastics and ebonite

ISO 179/1eA Determination of Charpy impact properties. Non-instrumented impact test

ISO 527–1 Determination of tensile properties - Part 1: General principles

ISO 527–2 Determination of tensile properties - Part 2: Test conditions for moulding and extrusion plastics

ISO 1183 Methods for determining the density of non-cellular plastics - Part 1: Immersion method, liquid pycnometer method and titration method

ISO 22621 Part 1 Plastics piping systems for the supply of gaseous fuels for maximum operating pressure up to and including 2 MPa (20 bar)—Polyamide (PA): General

ISO 13478 Thermoplastics pipes for the conveyance of fluids- Determination of resistance to rapid crack propagation (RCP) - Full-scale test (FST)

2.6 *Plastic Pipe Institute:*⁸

PPI TR3 Policies and Procedures for Developing Hydrostatic Design Basis (HDB), Pressure Design Basis (PDB), Strength Design Basis (SDB), and Minimum Required Strength (MRS) Ratings for Thermoplastic Piping Materials or Pipe

PPI TR4 Hydrostatic Design Bases and Maximum Recommended Hydrostatic Design Stresses for Thermoplastic Piping Materials

PPI TN7 Nature of Hydrostatic Stress Rupture Curves

PPI TR9 Recommended Design Factors for Pressure Applications of Thermoplastic Pipe Materials

PPI TR-45 Butt Fusion Joining Procedures for Field Joining of Polyamide-11

3. Terminology

3.1 *Definitions*—Definitions are in accordance with Terminology **F412**, and abbreviations are in accordance with Terminology **D1600**, unless otherwise specified.

3.2 The gas industry terminology used in this specification is in accordance with ANSI B31.8 or CFR OPS Part 192 Title 49, unless otherwise indicated.

3.3 The term *pipe* used herein refers to both pipe and tubing unless specifically stated otherwise.

3.4 *Definitions of Terms Specific to This Standard:*

3.4.1 *re-rounding equipment, n*—equipment used to reform the pipe and permanently reduce ovality to 5 % or less.

3.4.2 *rounding equipment, n*—equipment, devices, clamps, and so forth, used to temporarily hold the pipe round while out-of-roundness measurements are made, or a joining procedure (heat fusion, electrofusion, or mechanical) is performed.

3.4.3 *standard thermoplastic material designated code, n*—the pipe material designation code shall consist of the abbreviation for the polyamide (PA) followed by Arabic numerals which describe the short term properties in accordance with Classifications from **Table 2** followed by the hydrostatic design stress for water at 73.4 °F (23 °C) in units of 100 psi with any decimal figures dropped. Where the hydrostatic design stress code contains less than two figures, a zero is used before the number. Thus, a complete material designation code shall consist of two letters and five figures for polyamide 11 materials. For example, PA 32316 is a polyamide

⁴ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

⁵ Available from U.S. Government Publishing Office (GPO), 732 N. Capitol St., NW, Washington, DC 20401, <http://www.gpo.gov>.

⁶ DLA Document Services Building 4/D 700 Robbins Avenue Philadelphia, PA 19111-5094 <http://quicksearch.dla.mil/>

⁷ Available from International Organization for Standardization (ISO), 1, ch. de la Voie-Creuse, Case postale 56, CH-1211, Geneva 20, Switzerland, <http://www.iso.ch>.

⁸ Available from Plastics Pipe Institute (PPI), 105 Decker Court, Suite 825, Irving, TX 75062, <http://www.plasticpipe.org>.