

BS EN 54-27:2015



BSI Standards Publication

Fire detection and fire alarms systems

Part 27: Duct smoke detectors

bsi.

...making excellence a habit.™

National foreword

This British Standard is the UK implementation of EN 54-27:2015.

Clause 5.6.6 of this standard defines a non-operational leakage test method using under pressures - in excess of those observed in most ducts. However, in order to pass the test it is allowed to block the cable entries - thus excluding them from the leakage test. In some devices leakage through the cable entries may adversely affect the detector's sensitivity to smoke. Users are advised to consider the potential negative effects of leakage through the cable entries before deploying products approved to this standard.

The UK participation in its preparation was entrusted by Technical Committee FSH/12, Fire detection and alarm systems, to Technical Subcommittee FSH/12/2, Fire detectors.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2015.
Published by BSI Standards Limited 2015

ISBN 978 0 580 79691 3
ICS 13.220.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 May 2015.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------
