

INTERNATIONAL ELECTROTECHNICAL COMMISSION
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

IEC 60947-5-1
Edition 4.0 2016-05

IEC 60947-5-1
Édition 4.0 2016-05

Low-voltage switchgear and controlgear –

Appareillage à basse tension –

Part 5-1: Control circuit devices
and switching elements –
Electromechanical
control circuit devices

Partie 5-1: Appareils et éléments de
commutation pour circuits de commande –
Appareils électromécaniques
pour circuits de commande

CORRIGENDUM 1

5.2.2 Terminal identification and marking

5.2.2 Identification et marquage des bornes

Replace the existing text by the following new text:

Remplacer le texte existant par le nouveau texte suivant :

Subclause 7.1.8.4 of IEC 60947-1:2007 applies, with the additional requirements stated in Annex M.

Le Paragraphe 7.1.8.4 de l'IEC 60947-1:2007 s'applique, avec les exigences additionnelles identifiées dans l'Annexe M.

Table 8 – Immunity tests

Replace the existing table by the following new table:

Table 8 – Immunity tests

Type of test	Basic standard	Test level required		Acceptance criteria
Electrostatic discharge immunity test	IEC 61000-4-2	8 kV / air discharge or 4 kV / contact discharge		B ^k
Radiated radio-frequency electromagnetic field immunity test 80 MHz to 1 GHz	IEC 61000-4-3	10 V/m		A
Radiated radio-frequency electromagnetic field immunity test 1,4 GHz to 2 GHz	IEC 61000-4-3	3 V/m		A
Radiated radio-frequency electromagnetic field immunity test 2 GHz to 2,7 GHz	IEC 61000-4-3	1 V/m		A
Electrical fast transient/burst immunity test (with capacitive coupling clamp)	IEC 61000-4-4	2 kV / 5 kHz on power ports ^a 1 kV / 5 kHz on signal ports ^b		B ^k
Surge immunity test (1,2/50 μs - 8/20 μs) ^c	IEC 61000-4-5	2 kV (line to earth) 1 kV (line to line)		B
Conducted disturbances induced by radiofrequency fields immunity test (150 kHz to 80 MHz)	IEC 61000-4-6	10 V		A
Power frequency magnetic field immunity test ^d	IEC 61000-4-8	30 A/m		A
Voltage dips immunity test ^h	IEC 61000-4-11	Class 2 ^{e, f} 0 % during 0,5 cycle	Class 3 ^{e, f} 0 % during 0,5 cycle	B ^{k, l}
		Class 2 ^{e, f} 0 % during 1 cycle	Class 3 ^{e, f} 0 % during 1 cycle	B
		Class 2 ^{e, f, g} 70 % during 25/30 cycles	Class 3 ^{e, f, g} 40 % during 10/12 cycles 70 % during 25/30 cycles 80 % during 250/300 cycles	C
Voltage interruptions immunity test ^h	IEC 61000-4-11	Class 2 ^{e, f, g} 0 % during 250/300 cycles	Class 3 ^{e, f, g} 0 % during 250/300 cycles	C
Immunity to harmonics in the supply	IEC 61000-4-13	No requirements ⁱ		
^a Power port: the point at which a conductor or cable carrying the primary electrical power needed for the operation of the electronic circuit or the switching element or associated equipment is connected.				
^b Signal port: the point at which a conductor or cable carrying information for transferring data or signals is connected to the electronic circuit or the switching element.				
^c Not applicable for extra-low voltage a.c. ports (≤ 30 V) and extra-low voltage d.c. input/output ports (≤ 60 V), when the secondary circuits (isolated from the a.c. mains) are not subject to transient overvoltages.				
^d Applicable only to equipment containing devices susceptible to power frequency magnetic fields.				