

**Electricity metering – Payment systems –
Part 31: Particular requirements – Static payment meters for active energy
(classes 1 and 2)**

CORRIGENDUM 1

Page 55

C.8 Dielectric strength

Fourth bullet, on page 55:

Instead of: “impulse test voltage at 1 kV peak”

Read: “impulse test voltage at 2 kV peak”

Fifth bullet, on page 55:

Instead of: “a.c. test voltage at 2 kV r.m.s.”

Read: “a.c. test voltage at 1 kV r.m.s.”